




## TEST CERTIFICATE

### SUMMARY OF TEST RESULTS

<b>NUMBER</b>	<b>0414</b>	<b>DATE</b>	<b>08 /03 / 04</b>
---------------	-------------	-------------	--------------------

<b>Client' s data:</b>	<b>ALUMIL – MILONAS S.A.</b> Industrial Area Kilkis GR 611 00 KILKIS GREECE
<b>Product description:</b>	<b>SINGLE SASH DOOR OPENING / TILTING</b>
<b>Material:</b>	<b>ALUMINIUM</b>
<b>System :</b>	<b>M 9650 Alutherm Light</b>



2195 x 1000 mm

<b>Air Permeability</b> <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	<b>Class 4</b>
<b>Watertightness</b> <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	<b>Class E1050</b>
<b>Resistance to Wind Load</b> <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	<b>Class C4</b>

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.

**MARIANTHI CHATZIANTONIOU**  
**TECHNICAL MANAGER**

**IOANNIS GKERTSOS**  
**GENERAL MANAGER**

EXACT TRANSLATION FROM THE GREEK ORIGINAL