


SUMMARY OF RESULTS OF TESTING CERTIFICATE 0666 / 09.10.2006

NUMBER	0666	DATE	09 / 10 / 2006
---------------	------	-------------	----------------

Client' s data:	ALUMIL MYLONAS ALUMINIUM INDUSTRY S.A. KILKIS INDUSTRIAL AREA GR 611 00 KILKIS GREECE
Product description:	SINGLE SASH DOOR TILT & TURN
Material:	ALUMINIUM
System :	M - 940



950 x 2210mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 4
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class 8A
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C3

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOI PAPAPOPOULOU
LABORATORY MANAGER



IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL