


SUMMARY OF RESULTS OF TESTING CERTIFICATE 0664 / 06.10.2006

NUMBER	0664	DATE	06 / 10 / 2006
---------------	------	-------------	----------------


Client' s data:	ALUMIL MYLONAS ALUMINIUM INDUSTRY S.A. KILKIS INDUSTRIAL AREA GR 611 00 KILKIS GREECE
Product description:	DOUBLE SASH DOOR TILT & TURN
Material:	ALUMINIUM
System :	M - 940



1290 x 2210mm

Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 3
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class 7A
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class C2

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOPI PAPADOPOULOU
LABORATORY MANAGER



IOANNIS GKERTSOS
GENERAL MANAGER

EXACT TRANSLATION FROM THE GREEK ORIGINAL