


SUMMARY OF RESULTS OF TESTING CERTIFICATE 1166 / 27.07.2011

NUMBER	1166	DATE	27 / 07 / 2011
---------------	-------------	-------------	-----------------------

Client' s data:	Alumil S.A. ALUMINIUM INDUSTRY KILKIS INDUSTRIAL AREA GR 611 00 KILKIS GREECE
Product description:	DOUBLE SASH BALCONY DOOR SLIDING
Material:	ALUMINIUM
System :	M 14500



Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	Class 3
Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	Class 2B
Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	Class B3

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



SINOI PAPADOPOULOU
LABORATORY MANAGER



KONSTANTINOS KATSAROS
MANAGING DIRECTOR

EXACT TRANSLATION FROM THE GREEK ORIGINAL