


**SUMMARY OF RESULTS
OF TESTING CERTIFICATE 1165 / 26.07.2011**

| | | | |
|---------------|-------------|-------------|-----------------------|
| NUMBER | 1165 | DATE | 26 / 07 / 2011 |
|---------------|-------------|-------------|-----------------------|

| | |
|-----------------------------|--|
| Client' s data: | Alumil S.A. ALUMINIUM INDUSTRY KILKIS INDUSTRIAL AREA GR 611 00 KILKIS GREECE |
| Product description: | DOUBLE SASH BALCONY DOOR SLIDING |
| Material: | ALUMINIUM |
| System : | M 12000 |



1330 x 1950mm

| | |
|--|-----------------|
| Air Permeability <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i> | Class 2 |
| Watertightness <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i> | Class 3B |
| Resistance to Wind Load <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i> | Class C3 |

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOI PAPAPOPOULOU
LABORATORY MANAGER**



**KONSTANTINOS KATSAROS
MANAGING DIRECTOR**

EXACT TRANSLATION FROM THE GREEK ORIGINAL