


**SUMMARY OF RESULTS  
OF TESTING CERTIFICATE 0911 / 24.02.2009**

<b>NUMBER</b>	<b>0911</b>	<b>DATE</b>	<b>24 / 02 / 2009</b>
---------------	-------------	-------------	-----------------------

<b>Client' s data:</b>	<b>Alumil S.A.</b> <b>ALUMINIUM INDUSTRY</b> KILKIS INDUSTRIAL AREA GR 611 00 KILKIS GREECE
<b>Product description:</b>	<b>DOUBLE SASH DOOR SLIDING</b>
<b>Material:</b>	<b>ALUMINIUM</b>
<b>System :</b>	<b>M - 9200</b>



1290 x 2210mm

<b>Air Permeability</b> <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	<b>Class 3</b>
<b>Watertightness</b> <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	<b>Class 1B</b>
<b>Resistance to Wind Load</b> <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	<b>Class B3</b>

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOI PAPADOPOULOU**  
**LABORATORY MANAGER**



**IOANNIS GKERTSOS**  
**GENERAL MANAGER**

EXACT TRANSLATION FROM THE GREEK ORIGINAL