



NATIONAL CERTIFIED TESTING LABORATORIES

FIVE LEIGH DRIVE • YORK, PENNSYLVANIA 17406 • TELEPHONE (717) 846-1200
FAX (717) 767-4100
www.nctlinc.com

September 16, 2009

Alumil N.A. Corporation
4401 21st St., Suite 203
Long Island City, NY 11101
Attn: Kyp Bazenikas

Dear Mr. Bazenikas:

On August 20, 2009 tests were completed by our laboratory at our facility on the Alumil N.A. Corporation M3/M4 Curtain Wall System in accordance with the ASTM E 283, E 331, E 330 test methods and AAMA 501.1.

TEST RESULTS

Test Method	Title of Test	Measured
ASTM E 330	Preload to 50% of Design Pressure	N/A
ASTM E 283	Air Infiltration 6.24 psf (49 mph)	0.03 cfm/ft ²
ASTM E 331	Static Water Resistance 5.0 gph/ft ² WTP= 12.0 psf	No Leakage
ASTM E 330	** Uniform Load Structural-100% 35.0 psf exterior 35.0 psf interior	No Damage No Damage
AAMA 501.1	Dynamic Water Resistance 5.0 gph/ft ² WTP= 12.0 psf	No Leakage
ASTM E 283	Repeat-Air Infiltration 6.24 psf (49 mph)	0.03 cfm/ft ²
ASTM E 331	Repeat-Static Water Resistance 5.0 gph/ft ² WTP= 12.0 psf	No Leakage
ASTM E 330	** Uniform Load Structural-150%-Safety Factor 52.5 psf exterior 52.5 psf interior	No Damage No Damage

** No glass breakage or permanent damage causing the unit to be inoperable

TEST COMPLETED 08/20/09

A full report containing the details of the above referenced testing is forthcoming at the time of this letter. If you have any questions, please contact me at your convenience.

Sincerely,

NATIONAL CERTIFIED TESTING LABORATORIES

A handwritten signature in black ink, appearing to read "R. DeFayette", with a horizontal line extending to the right from the end of the signature.

ROBERT Wm. DeFAYETTE

Field Testing / Curtain Wall Coordinator